

seai SUSTAINABLE
ENERGY AUTHORITY
OF IRELAND
**ENERGY
SHOW**



follow us
#EnergyShow19



Rialtas na hÉireann
Government of Ireland

Edel Murray DHPLG: Overview of Part L



John Dolan, DoES: Schools



John Furlong, OPW: Leeson Lane



Frank Mills, ASHRAE: Net Zero Energy Buildings





An Roinn Tithíochta,
Pleanála agus Rialtais Áitiúil
Department of Housing,
Planning and Local Government

SEAI Energy Show

Part L and EPBD

Edel Murray
28th March 2019

Overview



State Forensic Science Laboratory, Kildare

Part L 2017: Conservation of Fuel and Energy – Buildings other than Dwellings

- NZEB and Major Renovation

2018 Amendments to EPBD (Energy Performance of Buildings Directive 2010/30/EU)

- EV Charging
- Building Automation and Control Systems
- Cost Optimal

NZEB – Buildings other than Dwellings



OPW Offices Leeson Lane

The **definition** for Nearly Zero Energy Buildings in the **EPBD 2010/30/EU** is as follows:
'Nearly zero-energy building means a building that has a very high energy performance. The nearly zero or very low amount of energy required should be covered to a very significant extent by energy from renewable sources, including energy from renewable sources produced on-site or nearby.'

Article 9 of the EPBD requires that Member States ensure that:

(a) by 31 December 2020, all new buildings are nearly zero-energy buildings; and

(b) after 31 December 2018, new buildings occupied and owned by public authorities are nearly zero-energy buildings.

Ireland carried out a cost optimal analysis in 2013 to define NZEB requirements.

NZEB for all new buildings is being implemented through Part L 2017, Conservation of Fuel and Energy – Buildings other than Dwellings.

Part L of the Buildings Regulations defines the requirements in legislation.

Circular issued to Public Sector in December 2016 with NZEB Interim Specification for buildings commencing design.

Energy Performance of Buildings Directive 2010/31/EU – Article 9

NZEB – Buildings other than Dwellings



State Forensic Science Laboratory, Kildare


Building Regulation Part L 2017 Conservation of Fuel and Energy – Buildings other than Dwellings

- **TGD L 2017** Conservation of Fuel and Energy – Buildings other than Dwellings:
 - Published: December 2017
 - Application: January 1st 2019 (subject to transitional arrangements)
 - Provides detailed NZEB guidance
 - Includes Major Renovation performance requirements to cost optimal level
- **Consultation with Stakeholders:**
 - Public Consultation and Regulatory Impact Analysis
 - OPW, DoES, HSE, SEAI, CIC
 - RIAI, SCS, EI, ACEI, CIF, CIBSE, IGBC, IBEC, ESB, Bord Gais
 - Multiple industry workshops with circa 1500 professionals



Energy Performance of Buildings Directive 2010/31/EU - Implementation

NZEB – Buildings other than Dwellings



OPW Offices Leeson Lane

TGD L 2017 Transitional Arrangements

- **TGD L 2017** applies to works, or buildings in which a material alteration or change of use or major renovation takes place, where the work, material alteration or the change of use commences or takes place, as the case may be, on or after 1st January 2019.
- **TGD L 2008 ceases** to have effect from **31st December 2018**.
- **TGD L 2008** may continue to be used in the case of buildings:
 - where the **work**, material alteration or the change of use **commences** or takes place, as the case may be, on or **before 31st December 2018, or**
 - where **planning approval** or permission for buildings has been applied for on or **before 31st December 2018**, and **substantial work** has been **completed by 1st January 2020**.

‘Substantial work has been completed’ means that the structure of the external walls has been erected.



Energy Performance of Buildings Directive 2010/31/EU - Implementation

NZEB – Buildings other than Dwellings



State Forensic Science Laboratory, Kildare

TGD L 2017

Key Components of Performance Requirements

- In the order of **60% improvement in energy performance** on the 2008 Building Regulations
- **Improved Fabric** Specification
- **Advanced Services and Lighting** Specification
- 20% requirement for renewable energy sources i.e. **Renewable Energy Ratio (RER)** of **20%** with flexibility to 10% where the building is more energy efficient than the Building Regulation requirement.
- **Major Renovation** performance requirements.



Energy Performance of Buildings Directive 2010/31/EU - Implementation

NZEB – Buildings other than Dwellings



OPW Offices Leeson Lane

TGD L Section 1.1 Limitation of Primary Energy Use and CO₂ emissions calculated using NEAP methodology to achieve:
MPEPC = 1.0
MPCPC = 1.15
 (equates to 60% reduction in energy performance)




TGD L Minimum Threshold level for Compliance:
RER = 0.20
Improved Building Fabric:
 U-Value Backstops
 Thermal Bridging ACDs
 Air Tightness = 5m³/(h.m²)
 Limit Solar Gain
Improved Building Services:
 Heat Generator Efficiency
 Controls for Space Heating & Hot Water
 ACMV System Efficiencies
 ACMV Controls
 Insulation of Storage Vessels, Pipes & Ducts
 Lighting Efficiency & Controls
Construction Quality & Commissioning of Services
User Information



Compliance with Part L Buildings other than Dwellings



Part L 2017
Achieving Compliance for New Buildings



Energy Performance of Buildings Directive 2010/31/EU - Implementation

NZEB – Buildings other than Dwellings



State Forensic Science Laboratory, Kildare

TGD L 2017 Reference Building Performance Requirements – Fabric Specification

Element	TGD L Reference Values
Total Floor Area & Building Volume	Same as actual building
Opening Areas	Offices & Shops: Windows and pedestrian doors are 40% of the total area of exposed walls
Walls	U-Value = 0.18W/m ² K
Roof	U-Value = 0.15W/m ² K
Floor	U-Value = 0.15W/m ² K
Thermal Bridging	Actual Length of Key Junctions x Advanced psi values
Air Permeability	5m ³ /(hr.m ²) Floor Area ≤ 250m ² 3m ³ /(hr.m ²) Floor Area > 250m ²
Window	U-Value = 1.4W/m ² K G-Value = 40%



Energy Performance of Buildings Directive 2010/31/EU - Implementation

NZEB – Buildings other than Dwellings



State Forensic Science Laboratory, Kildare

TGD L 2017 Reference Building Performance Requirements – Services Specification

Element	TGD L Reference Values/ Public Sector Specification
Heating Efficiency (Heating and hot water)	Gas Boiler 91% Efficiency
Cooling Seasonal Energy Efficiency Air conditioned Building Ratio (SEER)	SEER = 4.5/ SSEER = 3.6
Lighting	65 lm/circuit watt
Occupancy Control	Automated
Daylight Control	Automated
Central Ventilation SFP	1.8 W/(l/s)
Variable Speed Control of Fans	Yes
Renewable Energy Ratio using PV	0.2



Energy Performance of Buildings Directive 2010/31/EU - Implementation

NZEB – Buildings other than Dwellings



OPW Offices Leeson Lane

TGD L 2017 Renewable Energy Ratio (RER)

- Renewable energy requirement included in TGD L is based on **ISO 52000** where energy from **renewable sources is produced on site** or nearby.
- Standard Renewable Energy Ratio (RER) of 20% with flexibility to reduce to 10% where energy performance of the building is more energy efficient than the Building Regulation requirement.

$$RER = \frac{E_{PREN}}{E_{Ptot}}$$

E_{Ptot} is the total primary energy including renewable energy
 E_{PreN} is the renewable primary energy

- Renewable Energy Ratio Flexibility where:

MPEPC = 1.0	MPCPC = 1.15	RER ≥ 0.2
MPEPC = 0.9	MPCPC = 1.04	RER ≥ 0.1



Energy Performance of Buildings Directive 2010/31/EU - Implementation

NZEB – Buildings other than Dwellings



State Forensic Science Laboratory, Kildare

TGD L 2017 Fabric

- Airtightness backstop $\leq 5\text{m}^3/(\text{hr.m}^2)$
- **Air tightness testing is a requirement on building completion.** Alternative approach for confirming compliance is only permitted for large complex buildings with a building envelope area in excess of 160,000m².
- **Air tightness testers to be certified** by Irish National Accreditation Board (INAB) or National Standards Authority of Ireland (NSAI), to **I.S. EN ISO 9972**.
- **Overheating check in NEAP software**; and detailed checks to use CIBSE TM52.
- Solar gain reference case in NEAP is an east-facing façade with full width glazing to a height of 1m having a framing factor of 10% and a normal solar energy transmittance (G-Value) of 0.68.



Energy Performance of Buildings Directive 2010/31/EU - Implementation

NZEB – Buildings other than Dwellings



OPW Offices Leeson Lane

TGD L 2017: Section 2 Existing Buildings

- Works Categories:
 - Extensions
 - Material Alterations
 - Material Change of Use
 - Major Renovations



Energy Performance of Buildings Directive 2010/31/EU - Implementation

NZEB – Buildings other than Dwellings



State Forensic Science Laboratory, Kildare

TGD L 2017: Section 2 Existing Buildings: Fabric

- **Extensions** - Refer to **Table 1** (as per new buildings)

Table 1 Maximum elemental U-value ¹ (W/m ² K)		
Column 1 Fabric Elements	Column 2 Area – weighted Average Elemental U-Value (U _m)	Column 3 Average Elemental U-value Individual element or section of element
Roofs ²		
Pitched roof		
- Insulation at ceiling	0.16	
- Insulation on slope	0.16	0.3
Flat roof	0.20	
Walls ²	0.21	0.6
Ground Floors ^{2,3}	0.21	0.6
Other exposed floors ²	0.21	0.6
External personnel doors, windows ⁴ and rooftlights ⁵	1.6 ⁵	3.0
Curtain Walling	1.8	3.0
Vehicle access and similar large doors	1.5	3.0
High usage entrance door ⁷	3.0	3.0
Swimming Pool Basin ⁸	0.25	0.6

Conservation of Fuel and Energy - Buildings other than Dwellings

L

Building Regulations 2017

Technical Guidance Document

An Roinn Tithíochta, Pleanála, Traidise agus Stádas Áite
Department of Housing, Planning, Community and Local Government

Energy Performance of Buildings Directive 2010/31/EU - Implementation

NZEB – Buildings other than Dwellings




OPW Offices Leeson Lane

TGD L 2017: Section 2 Existing Buildings: Fabric

- **Material Alterations** – Refer to **Table 10** specific to this category

Table 10 Maximum elemental U value (W/m ² K) ^{1,2} for Material Alterations		
Column 1 Fabric Elements	Column 2 Area-weighted Average Elemental U-Value (Um)	Column 3 Average Elemental U-value – individual element or section of element
Roofs		
Pitched roof - Insulation at ceiling - Insulation on slope	0.16 0.25	0.35
Flat roof	0.25	
Walls		
Cavity Walls ³ Other Walls	0.55 0.35	0.60
Curtain Walls	1.8	0.60
Ground Floors		
	0.45 ^{4,5}	
Other Exposed Floors ⁵	0.25	0.60
External doors, windows and rooflights	1.60	3.0



Energy Performance of Buildings Directive 2010/31/EU - Implementation

NZEB – Buildings other than Dwellings



State Forensic Science Laboratory, Kildare

TGD L 2017: Section 2 Existing Buildings: Fabric

- **Material Change of Use** – Refer to **Table 11** specific to this category

Table 11 Maximum elemental U value (W/m ² K) ¹ for Material Change of Use for retained elements			
Column 1 Fabric Elements	Column 2 Area-weighted Threshold Elemental U-Value (U _t)	Column 3 Area-weighted Average Elemental U-Value (U _m)	Column 4 Average Elemental U-value – individual element or section of element
Roofs			
Pitched roof			
- Insulation at ceiling	0.16	0.16	0.35
- Insulation on slope	0.35	0.25	
Flat roof	0.35	0.25	
Walls			
Cavity Wall ³	0.55	0.55	0.60
Other Walls	0.55	0.35	
Curtain Walls (frame and centre panels)	3.6	1.8	3.0
Ground Floors	-	-	-
	0.45	0.45 ^{4,5}	
Other Exposed Floors	0.6	0.25	0.60
External doors, windows and rooflights	3.6	1.6 ²	3.0



Energy Performance of Buildings Directive 2010/31/EU - Implementation


NZEB – Buildings other than Dwellings



OPW Offices Leeson Lane

TGD L 2017: Section 2 Existing Buildings: Major Renovation

- Where more than **25% of the surface area of the building envelope** undergoes renovation the energy performance of the whole building should be improved to Cost Optimal level in so far as this is technically, functionally and economically feasible.
- Works to the surface area of the building include the following:
 - **Cladding** the external surface of an element
 - **Drylining** the internal surface of an element
 - **Replacing windows**
 - Stripping down the element to **expose the basic structural components** (brickwork/ blockwork, timberframe, steelframe, joists, rafters, purlins, etc.) and then rebuilding to achieve all the necessary performance requirements.



Energy Performance of Buildings Directive 2010/31/EU - Implementation

NZEB – Buildings other than Dwellings



State Forensic Science Laboratory, Kildare

TGD L 2017: Section 2 Existing Buildings: Major Renovation

The following **improvements** are normally **considered to be cost optimal** and will typically be economically feasible when more than 25% of the surface area of a building is upgraded:

- **Upgrading oil, gas or biomass heating systems** more than 15 years old and with an efficiency of less than that shown in Table 2;
- **Upgrading controls for direct electric space heating systems** to achieve the level of controls described in Table 5;
- **Upgrading cooling and ventilation systems** more than 15 years old and a cooling unit Seasonal Energy Efficiency Ratio less than that in the Eco-design Regulation referenced in par 1.4.3.11 and / or Specific Fan Power greater than that in Table 12 and by the provision of new plant; and
- **Upgrading general lighting systems** that are more than 15 years old or have an average lamp efficacy of less than 40 lamp-lumens per circuit-watt as defined in NEAP and that serves greater than 100m² to the guidance in section 2.2.7.



Energy Performance of Buildings Directive 2010/31/EU - Implementation

NZEB – Buildings other than Dwellings



OPW Offices Leeson Lane

TGD L 2017: Section 2 Existing Buildings: Major Renovation

Table 13 Whole Building Cost Optimal Level	
Building Type	Major Renovation - Cost Optimal Performance kWh/m ² /yr primary energy
Retail Air Conditioned	338
Office Natural Ventilated offices and other Buildings	124
Office Air Conditioned	180
Hotel Air Conditioned	342
Schools	60
Other Air Conditioned Buildings	338
Other Naturally Ventilated Buildings	124

Alternatively where the **whole building** performance achieves the **primary energy performance levels as calculated in NEAP** and specified in **Table 13** where technically, functionally and economically feasible this can be considered the cost optimal level of performance.



Energy Performance of Buildings Directive 2010/31/EU - Implementation

NZEB – Buildings other than Dwellings




State Forensic Science Laboratory, Kildare

TGD L 2017

NEAP (Non-Domestic Energy Assessment Procedure)

- NEAP is the **methodology for demonstrating compliance with Part L** of the Building Regulations and **publishing Building Energy Ratings (BERs)**.
- The **NEAP software** in the form of the Simplified Building Energy Model for Ireland (**SBEMie**) has been updated to demonstrate compliance with NZEB and Part L of the Building Regulations. The new software **SBEMie version 5.5h** developed by BRE was made available to download from the SEAI website on 30th November 2018.
- HVAC **process loads capped for RER** calculation.
- **New schedules** included in SBEMie version 5.5h for **healthcare specialist areas**.
- **New schedules** included in SBEMie version 5.5h **for schools**.
- **Primary Energy Factor (PEF) is 2.08**
- **CO₂ Emissions Factor** is **0.409kgCO₂/kWh**



Energy Performance of Buildings Directive 2010/31/EU - Implementation

Overview



OPW Offices Leeson Lane

2018 Amendments to EPBD (Energy Performance of Buildings Directive 2010/30/EU)

- EV Charging
- Building Automation and Control Systems
- Cost Optimal

Energy Performance of Buildings Directive 2010/31/EU & Amending Directive 2018/844 – Articles 8, 14 & 15

EV Charging – EPBD Requirement in Building Regulations



TGD L 2017: Amendment
EV Charging for New Buildings – application date 10th March 2020

Scope		MS Obligation
New Buildings	Non-residential buildings with more than 10 no. parking spaces	<ul style="list-style-type: none"> Ensure the installation of at least 1 no. recharging point Ensure the installation of ducting infrastructure for at least 1 in 5 no. parking spaces
and		
Buildings undergoing Major Renovation	Residential buildings with more than 10 no. parking spaces	Ensure the installation of ducting infrastructure for every parking space
Existing Buildings *	Non-residential – all buildings with more than 20 no. parking spaces	Lay down requirement for the installation of a minimum number of recharging points – applicable from 2025

Energy Performance of Buildings Directive 2010/31/EU & Amending Directive 2018/844 – Article 8

BACS – EPBD Requirement in Building Regulations



State Forensic Science Laboratory, Kildare


TGD L 2017: Amendment BACS

- EPBD Definition:
'**Building Automation and Control System** means a system comprising all products, software and engineering services that can support energy efficient, economical and safe operation of technical building systems through automatic controls and by facilitating the manual management of those technical building systems'.
- EPBD Requirement:
Member States shall lay down requirement to ensure that, where technically and economically feasible, **non-residential buildings with an effective rated output for heating systems or systems for combined space heating and ventilation of over 290kW are equipped with building automation and control systems by 2025.**
- The requirement applies to all buildings i.e. new and existing ones, when they meet the criterion on the effective rated output. The **290kW threshold applies to each system individually.**



Energy Performance of Buildings Directive 2010/31/EU & Amending Directive 2018/844 – Articles 14 & 15

BACS – EPBD Requirement in Building Regulations



OPW Offices Leeson Lane

TGD L 2017: Amendment BACS

- The building automation and control systems shall be capable of:
 - continuously **monitoring, logging, analysing** and allowing for **adjusting energy use**;
 - **benchmarking the buildings energy efficiency, detecting losses** in efficiency of technical building systems, and **informing the person responsible** for the facilities or technical building management **about opportunities for energy efficiency improvement**; and
 - **allowing communication with connected technical building systems** and other appliances inside the building, and being **interoperable with technical building systems** across different types of proprietary technologies, devices and manufacturers.



Energy Performance of Buildings Directive 2010/31/EU & Amending Directive 2018/844 – Articles 14 & 15

Cost Optimality – EPBD Requirement in Building Regulations



State Forensic Science Laboratory, Kildare

Cost Optimal

- Each Member State has a responsibility to set minimum requirements for the energy performance of buildings and building elements. Those requirements are set with a view to achieving the **cost-optimal balance between the investments involved and the energy costs saved throughout the lifecycle of the building**. The cost-optimal level must lie within the range of performance levels where the cost benefit analysis calculated over the estimated economic lifecycle is positive.
- Each Member State must regularly review their minimum energy performance requirements, i.e. **every 5 years**, for buildings in light of **technical progress**.
- Cost optimal calculations differentiate between **new and existing buildings** and between **different categories of buildings**.
- **TGD L 2017** building fabric and services performances were based on the results of the **2013 Cost Optimal Calculations**.
- **Cost Optimal Calculations 2018/ 2019** are in progress with a view to **publication in Q1 2019**. This has involved a detailed review of specifications for building fabric and services in conjunction with key stakeholders e.g. HSE, DoES, OPW, SEAI, etc.



Energy Performance of Buildings Directive 2010/31/EU

NZEB – Buildings other than Dwellings



Thank you for your attention.



An Roinn Tithíochta,
Pleanála agus Rialtais Áitiúil
Department of Housing,
Planning and Local Government



[Home](#) [Who We Are](#) [What We Do](#) [Publications](#) [Legislation](#) [Statistics](#)

[Home](#) / [Building Regulations 2017 - Technical Guidance Document L - Buildings other than Dwellings \(Operative w.e.f. 1 Jan. 2019\)](#)

[Printer-friendly version](#)

Building Regulations 2017 - Technical Guidance Document L - Buildings other than Dwellings (Operative w.e.f. 1 Jan. 2019)

 [Building Regulations 2017 - Technical Guidance Document L - Buildings other than Dwellings \(Operative w.e.f. 1 Jan. 2019\) \(1.89 MB\)](#)

Category

[Housing](#)

Topic

[Building Standards](#)

Sub topic

[TGD Part L - Conservation of Fuel and Energy](#)

Website: www.housing.gov.ie

Email: Buildingstandards@housing.gov.ie

Delivering nearly Zero Energy Schools

John Dolan

Department of Education and Skills



Delivering nearly Zero Energy Schools

John Dolan
BEng (Hons) M.Sc. Fire Eng
H.Dip CEng MIEI
Chartered Engineer

Planning & Building Unit
Tullamore

www.energyineducation.ie



An Roinn Oideachais
agus Scileanna
Department of
Education and Skills

seai SUSTAINABLE
ENERGY AUTHORITY
OF IRELAND
**ENERGY
SHOW**

Delivering nearly Zero Energy Schools

- **Our energy policy & design approach**
- **Research projects informing approach to achieving new energy regulation targets**
- **Delivery through TGD 033**
- **Implementation**



An Roinn Oideachais
agus Scileanna
Department of
Education and Skills

Delivering nearly Zero Energy Schools

- **Our energy policy & design approach**



*SEAI Sustainability in the
Built Environment Award
2012*



An Roinn Oideachais
agus Scileanna
Department of
Education and Skills



Delivering nearly Zero Energy Schools



An Roinn Oideachais
agus Scileanna
Department of
Education and Skills

- evolved from energy programme DART (Design, Awareness, Research & Technology)
- informed by building unit professional & technical staff & external partnerships
- driven by technical guidance documents
- updated by continued energy research & development
- disseminated via publications, conferences & annual report
- specific project support from SEAI
- acknowledged by national & international energy awards

Delivering nearly Zero Energy Schools



An Roinn Oideachais
agus Scileanna
Department of
Education and Skills

- schools needs: not same as domestic/
commercial market needs (different operational profiles)
- short hours of operation
- technical ability on site
- energy not core function
- solutions must be simple and robust



renewables in schools



energy in education
Promoting energy efficiency in schools
A partnership initiative of SEAI and DES

Information for Schools

Information for Designers, Contractors and School Boards of Management

Energy in Education

The Energy in Education website is one of a range of supports developed by the Sustainable Energy Authority of Ireland (SEAI) in collaboration with the Department of Education and Skills designed to help school boards of management, principals, teachers, administrators, caretaking staff, pupils and parents to improve energy use practices and to reduce school operating costs along with helping to protect the environment for future generations.

There is a statutory requirement for public sector organisations to reduce energy consumption by 33% by 2020. Public bodies, including schools, will also be obliged to monitor and report energy use to SEAI from 2011.

Remember to switch off all your energy consuming equipment before the holidays. Click [here](#) for our summer shut down factsheet

Find Savings

Linking to Green-Schools

Energy management Getting Started

Involve Pupils Teaching Resources

Measure Energy Use

Get a Display Energy Certificate

www.energyineducation.ie



An Roinn Oideachais
agus Scileanna
Department of
Education and Skills

Delivering nearly Zero Energy Schools

-
- **Research projects informing approach to achieving new energy regulation targets**
-
-



An Roinn Oideachais
agus Scileanna
Department of
Education and Skills

Delivering nearly Zero Energy Schools

*Energy Research Programme projects
that informed approach*



Colaiste Choilm,
Tullamore - 2007



Moynalty NS,
Meath &
Powerscourt NS,
Wicklow - 2009



St Patrick's NS,
Greystones -
2013



St Catherine's
NS, Auhtrim -
2016



An Roinn Oideachais
agus Scileanna
Department of
Education and Skills

Delivering nearly Zero Energy Schools

-
-
- **Delivery through TGD 033**
-



An Roinn Oideachais
agus Scileanna
Department of
Education and Skills




Backstop v's Reference U values

Delivery through TGD 033



An Roinn Oideachais
agus Scileanna
Department of
Education and Skills

Delivery through TGD 033



An Roinn Oideachais
agus Scileanna
Department of
Education and Skills

NZEB design priorities

Passive architectural design principles

Energy efficient envelope and technologies

Modelling & SBEM




An Roinn Oideachais
agus Scileanna
Department of
Education and Skills

NZEB design priorities

Passive architectural design principles



Energy efficient envelope and technologies



Modelling & SBEM



An Roinn Oideachais
agus Scileanna
Department of
Education and Skills

Delivering nearly Zero Energy Schools

Maximising Nature

passive
solar
design

daylighting

quality
ventilation

Technologies

enhanced
U values

air
tightness

lighting &
controls

heating &
controls

water
efficiency

Delivering nearly Zero Energy Schools

Delivery through TGD 033



Maximising Nature



Technologies

- ✓ enhanced U values
- ✓ air tightness
- ✓ lighting & controls
- heating & controls
- water efficiency
- ✓ enhanced glazing
- ✓ Condensation risk analysis
- ✓ Renewable Energy
- ✓ Thermal Bridging



**SBEM 3.5a
compatibility
with Irish
Schools**

*hot water
demand*

*density
ratios in
classrooms*

*occupancy
hours*

*occupancy
rates*

*internal
design
temperature*



An Roinn Oideachais
agus Scileanna
Department of
Education and Skills



**SBEM 3.5a
compatibility
with Irish
Schools**

*hot water
demand*

*density
ratios in
classrooms*

*occupancy
hours*

*occupancy
rates*

*internal
design
temperature*

**SBEM 5.5h
more
compatible for
Irish Schools**



An Roinn Oideachais
agus Scileanna
Department of
Education and Skills

Delivering nearly Zero Energy Schools

-
-
-
- **Implementation**



An Roinn Oideachais
agus Scileanna
Department of
Education and Skills

Delivering nearly Zero Energy Schools *Implementation*

Roof Type Example: Pitched roof (Insulation on Slope)



***Metal Deck on
Open cell insulation on
Single membrane on
Support Deck***

TGD 033 requirements for roofs equates to approx. 235mm thickness Mineral Wool insulation.

Delivering nearly Zero Energy Schools *Implementation*

DoES policy is to minimise/ remove, where possible, roof penetrations and ext. equipment

Roof design considerations

- Suitability of roof finish and fixing methodology for PV and potential for additional structural requirements



New build



Retrofit



Delivering nearly Zero Energy Schools *Implementation*

Roof design considerations


- Suitability of roof finish and fixing methodology for PV and potential for additional structural requirements
- Inspection/Maintenance requirements



Delivering nearly Zero Energy Schools *Implementation*

Roof design considerations


- Suitability of roof finish and fixing methodology for PV and potential for additional structural requirements
- Inspection/maintenance requirements
- Access to the roof / emergency escape



Delivering nearly Zero Energy Schools *Implementation*

Roof design considerations

- Suitability of roof finish and fixing methodology for PV and potential for additional structural requirements
- Inspection/maintenance requirements
- Access to the roof / emergency escape from roof
- Robustness of roofing specification for footfall on access zones: Impact on manufacturers warranties



Delivering nearly Zero Energy Schools *Implementation*

Roof design considerations

- Suitability of roof finish and fixing methodology for PV and potential for additional structural requirements
- Inspection/maintenance requirements
- Access to the roof / emergency escape from roof
- Robustness of roofing specification for footfall on access zones: Impact on manufacturers warranties
- **Roof design and removal of risk of fall (parapet) Vs mitigation of risk of fall from height (fall arrest system)**

Avoid



Delivering nearly Zero Energy Schools

A CO² monitor in all teaching spaces enabling the users to be aware of CO² levels enabling intervention to maintain the comfort levels and air quality

Vampire Load system automatically links the school electrical system to the intruder alarm & shuts down power to non-essential electrical power outlets when alarm is activated



Backstop v's Reference U values

Delivery through TGD 033

How low can we go !!!

4% reduction in primary energy

the proportion of heat loss through these elements is low in a school building

Saving pa for opaque heat losses

€89 for 16 class primary school

€303 for 800 pupil Post Primary



Delivering nearly Zero Energy Schools

Modelled School Building Energy improvement over the new 2017 Building Regulations.

800 pupil Post Primary school 20%

16 Classroom Primary School 18.5%



An Roinn Oideachais
agus Scileanna
Department of
Education and Skills

Delivering nearly Zero Energy Schools

John Dolan
BEng (Hons) M.Sc. Fire Eng
H.Dip CEng MIEI
Chartered Engineer

Planning & Building Unit
Tullamore

www.energyineducation.ie



An Roinn Oideachais
agus Scileanna
Department of
Education and Skills

Delivering a Commercial Nearly Zero Energy Building



John Furlong

OPW



AGENDA

- (1) Introduction
- (2) Nearly Zero Energy Buildings (NZEB)
- (3) Building Regulations TGD Part L 2017
- (4) Case Study:
City Centre Office Building
- (5) Conclusion



AGENDA



(1) Introduction

(2) Nearly Zero Energy Buildings (NZEB)

(3) Building Regulations TGD Part L 2017

(4) Case Study:

City Centre Office Building

(5) Conclusion



(1) INTRODUCTION



Office Of Public Works

- Responsible for managing the property portfolio for central government.
 - Build, Lease
 - Operate & Maintain
- Energy Conservation Programmes delivered savings of more than 20 % in energy consumption.

AGENDA



(1) Introduction

(2) Nearly Zero Energy Buildings (NZEB)

(3) Building Regulations TGD Part L 2017

(4) Case Study:

City Centre Office Building

(5) Conclusion



(2) Nearly Zero Energy Buildings (NZEB)

EUROPEAN PERFORMANCE OF BUILDINGS DIRECTIVE RECAST & NZEB

2010/31/EU Article 2 Definitions:

'nearly zero-energy building'

"means a building that has a very **high energy performance**.

The nearly zero or very low amount of energy required should be covered to a very significant extent by **energy from renewable sources**, including energy from renewable sources produced on-site or nearby;"

What does this mean to you?

- Architects
- Structural Engineers
- Building Services Engineers
- Quantity Surveyors
- Main Contractors
- Mechanical Contractors
- Electrical Contractors
- Building Owners / Developers (Public and Private Sector)
- Building Occupants
- Facilities Management

AGENDA




- (1) Introduction
- (2) Nearly Zero Energy Buildings (NZEB)
- (3) Building Regulations TGD Part L 2017**
- (4) Case Study:
City Centre Office Building
- (5) Conclusion

(3) Building Regulations TGD Part L 2017

Introduction

- Came into effect on the 1st January 2019
 - Limit Primary Energy Consumption & related CO2 emissions to a **Nearly Zero Energy Building (NZEB)** as calculated using the NEAP as published by SEAI and that the nearly zero energy is covered to a significant extent by renewable energy produced on site or nearby.
- Energy Performance Coefficient MPEPC = 1.0
 - Carbon Performance Coefficient MPCPC = 1.15
 - Renewable Energy Ratio RER = 0.2 or 0.1 (EPC=0.9)
- Equates to approx. an improvement in the order of 60 % over a Part L 2008 building with 20 % of its energy produced on site.



L

**Building
Regulations
2017**

**Technical
Guidance
Document**

(3) Building Regulations TGD Part L 2017

Renewable Energy Technologies

- Solar Thermal Systems,
- Photovoltaic Systems,
- Biomass Systems
- Systems using Bio Fuels
- Heat Pumps
- Combined Heat & Power
- Aerothermal
- Geothermal
- Hydrothermal
- Wind
- Biomass and Biogases and
- Other on site renewables



(3) Building Regulations TGD Part L 2017

Limiting the effects of solar gain in summer

- Applies to all buildings to reduce the need for air-conditioning or to reduce the capacity of any air conditioned system that is installed.
- The solar gains in each space occupied or cooled aggregated from April to September are no greater than would occur through a given glazing system with a total solar energy transmittance (g-value).
 - E.g. A east facing façade with 1m high glazing and a g-value of 0.68

Limiting Overheating

The assessment of solar gain is not an assessment of internal comfort as there are many other factors to be considered and therefore CIBSE TM 52 should be used to ensure overheating is avoided for naturally ventilated spaces.

AGENDA



- (1) Introduction
- (2) Nearly Zero Energy Buildings (NZEB)
- (3) Building Regulations TGD Part L 2017

(4) Case Study:

City Centre Office Building

- (5) Conclusion

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING

- Leeson Lane: 6,500 m² (7 storey)
- Potential for Natural Ventilation
- Planning Stage 2016 (Pre NZEB)
- Design Team Target to achieve 60 % reduction in energy without renewables

40 % is achievable with cost optimal building envelope and building services




(4) CASE STUDY: CITY CENTRE OFFICE BUILDING




SITE AND CONTEXT

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING



SITE AND CONTEXT

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING




SITE AND CONTEXT

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING



SITE AND CONTEXT

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING



Shallow Plan and Flexible Layout

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING


Approach to Reducing Energy Consumption & CO2 Emissions:

- (1)** Establish optimal Fabric, Facade and Building Envelope Design
- (2)** Establish optimal Heating, Ventilation & Air Conditioning (HVAC) Strategy
- (3)** Establish optimal Renewable Energy Strategy

Utilisation of Building Performance Modelling to assist in the strategies above.

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING


(1) Establish optimal Fabric, Facade and Building Envelope Design



MAXIMISE DAYLIGHT – PARTICULARLY ON LOWER LEVELS ADJACENT TO THE NURSES BUILDING

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING

TAILORED FACADE DESIGN




75%
Glass

75% Glass with
External Shading

66% Glass set back by 300 mm with vertical fins,
low e glazing, frit and insulated opaque panels

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING

TAILORED FACADE DESIGN



FACADE BAY WITH 2 NO. NATURAL VENTILATION ZONES

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING

(2) Optimum Heating Ventilation & Air Conditioning (HVAC) Strategy:

- Typical Building in Dublin.
- However Leeson Lane is not typical.
- Natural ventilation is a less energy intensive solution.


(4) CASE STUDY: CITY CENTRE OFFICE BUILDING

(2) Optimum Heating Ventilation & Air Conditioning (HVAC) Strategy:

- Ability to open windows in buildings and connect with the outside is a benefit for the occupants.
- Direct control over their environment

Leeson Lane is essentially a shallow plan and all occupants are located within 4 – 5 m of a natural ventilation opening.

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING



Percentage of Time Temperature exceeded:-

20 °C = 12 %

25 °C = 3 %


Highest Recorded Temperature =

38.1 °C

(2003, Kew Gardens)

Review of climate – London Versus Dublin

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING



Percentage of Time
Temperature exceeded:-

20 °C = 1.5 %

25 °C = 0.1 %

Highest Recorded
Temperature =

28.1 °C
(1990, Dublin Airport)

Review of climate – London Versus Dublin

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING

Optimum Heating Ventilation & Air Conditioning (HVAC) Strategy:

Option 1: Natural ventilation with ceiling tile finish.

Option 1A: “Hybrid” ventilation with ceiling tile finish and night time purging using AHU’s plus comfort cooling in meeting rooms.

Option 2: “Hybrid” ventilation with exposed concrete and a night time purging using AHU’s plus comfort cooling in meeting rooms.

Option 3: “Hybrid” ventilation with embedded coils (i.e. to provide background cooling)

Option 4: Comfort Air conditioning with fan coil units (FCU’s)

Option 5: Comfort Air conditioning with Active Chilled Beams


Option 6: Hybrid ventilation with ceiling mounted radiant panels for background cooling.

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING

Part L 2017: 1.3.6 Limiting Overheating:


- Refers to CIBSE TM52 (2013) The Limits of Thermal Comfort – Avoiding Overheating in European Buildings, which is based on the adoption of EN 15251.
- This superseded a single temperature and fixed percentage of hours approach as given in CIBSE 2006 Guide A.
- The common industry standard was to apply a limit of 1 % of occupied hours where the internal temperature exceeded 28 oC and 5 % of the occupied hours where the internal temperature exceeded 25 oC.
- It was recognised that the single temperature approach did not work for all climates and buildings.
- Therefore the adaptive approach for “free running” buildings was introduced.

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING



CIBSE TM 52 versus CIBSE 2006

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING



CIBSE TM 52 versus CIBSE 2006

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING

South West Facing Room
G-Value=
0.23
at 6.30 PM
on the 16th
July

Select method: PMV method

Air temperature: 25 °C Use operative temperature

Mean radiant temperature: 30 °C

Air speed: 0.1 m/s Local air speed control


Humidity: 60 % Relative humidity

Metabolic rate: 1 met Seated, quiet: 1.0

Clothing level: 0.5 clo Typical summer indoor

Create custom ensemble

Globe temp Specify pressure Set defaults SI IP Local discomfort ? Help



Impact of g-value on internal comfort

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING

South West Facing Room
 G-Value=
 0.37
 at 6.30 PM
 on the 16th
 July

Select method: PMV method

Air temperature: 25 °C

Mean radiant temperature: 34 °C

Air speed: 0.1 m/s

Humidity: 60 %

Metabolic rate: 1 met

Clothing level: 0.5 clo

Seated, quiet: 1.0

Typical summer indoor

Create custom ensemble

Globe temp Specify pressure Set defaults SI IP Local discomfort ? Help

X Does not comply with EN-15251

PMV 1.32

PPD 41%

Category IV

Psychrometric chart (air tempera

t_{db} 0.0 °C



rh 0.0 %

W_a 0.0 g w/kg da

t_{wb} 0.0 °C

t_{dp} 0.0 °C

h 0.0 kJ/kg



Impact of g-value on internal comfort

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING

(3) Review of Renewable Energy Options:-

Item	Description	Result	Comments
1	Gas Boiler & PV (242m2)	Fail	No planning & no space on roof for PV.
2	Gas Boiler & PV (242m2)	Fail	No planning & no space on roof for PV.
3	Heat Pumps & No PV	Pass	Heat Pumps meet the renewable requirement.
4	Heat Pumps & No PV	Pass	Heat Pumps meet the renewable requirement.
5	CHP	Fail	Assessed in 2017.
6	Solar Panel	Fail	Assessed in 2017
7	Biomass	Pass	Assessed in 2017, not suitable for city centre location.
8	Biogas CHP	Pass	Assessed in 2017, lack of availability of Biogas.

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING

Air Source Heat Pumps:-



- Many options such as Heat Pump only, Heating and Cooling - 2 pipe and 4 pipe.
- Profiling heating and cooling loads and possible simultaneous use.
- Not a simple like for like replacement for traditional gas fired boilers.
- Produce low grade heat – Delta T, pipework and emitter sizing and pump power.
- Potential weakness: Heating capacity and efficiency diminish as the external temperature drops.
- Availability of manufacturers data (part load efficiency) and technical support.
- Use of bivalent systems – In England and Wales TGD under Part L4 Heat Pumps should only be used when the COP exceeds 2.2.
- Use of night rate electricity and thermal mass and or phase change systems.
- Plant space on roof versus basement and planning restrictions
- Maintenance, resilience and life cycle costs.

(4) CASE STUDY: CITY CENTRE OFFICE BUILDING

Air Source Heat Pumps:-

- Monovalent v's Bivalent Use

Efficiency (EN 14511 Full Load; Part Load: EN14825?)




(4) CASE STUDY: CITY CENTRE OFFICE BUILDING


- **SBEM 5.5 h**
- Released in December 2018
- Integration into dynamic simulation packages is ongoing.
 - For example IES has yet to get their module validated.
 - Working with the Beta version is giving rise to some surprising results.
- Cannot be used to generate BER certificates.

(5) CONCLUSION

- Integrated Design Approach
- Provide good indoor environmental quality (IEQ)
- TGD Part L: NZEB & Renewable Energy Requirements
- Carbon Emissions Reductions
 - Carbon Intensity of the Electrical Grid



(5) CONCLUSION – PARTING THOUGHT



Thank You!

Questions



The Sustainable Energy Authority of Ireland is partly financed by Ireland's EU Structural Funds Programme co-funded by the Irish Government and the European Union.



International Perspective

Frank Mills

ASHRAE



Agenda

- Why Net Zero ?
- International Net Zero targets
- What is Net Zero ?
- Who have already completed Net Zero Buildings?
- Strategies to achieve Net Zero
- Hospitals – special case
- Zero energy cities
- Net Zero performance
- Conclusions – ASHRAE design tools

Why Net Zero ?

1. Energy costs rising—save money
2. Fuels running out—conserve, last longer - UK gas runs out in 2 years time
3. Health, well being, and pollution. Lots of data on life expectancy and health
4. Global warming impacts – disasters coming

Heat or Eat Dilemma

- UK Households at risk of food and fuel poverty as “heat or eat” dilemma proves real
- Food banks are out of reach for some rural families
- Why have such a problem in a country which wastes so much energy


UK Wastes over £30 Billion Each Year by Heat Rejection from Power Stations

Power stations convert only 33% of the input energy into electricity. The rest is rejected as waste heat.

**Enough to Heat
whole of Britain –
for free**

Kim Westerskov

CO₂ and Global Warming




Burning Up Fossil Fuels




**Earth's resource of oil used up
in less than 200 years?**

Oil reserves exhausted in 40 years??
CO₂ levels will continue to rise for 100 years


Melting Ice Caps and Glaciers




Melting Ice Caps and Glaciers




Global Warming



Global Warming



How High Will Sea Levels Rise?



Coastal cities like London and New York could sink?

How High Will Sea Levels Rise?



Tampa, FL—1.5 m Sea Rise



New York City, NY—3-5 m Sea Rise



San Francisco, CA—2.25 m Sea Rise



Miami Beach, FL—1 m Sea Rise

NZEB – European definitions

National requirements given by the EPBD directive

From REHVA journal March 2014

Ireland included


Table 1. Overview of the NZEB numerical definition currently available in Europe.

Zone	Country	NZEB definition					RES
		Energy Performance (EP)					
		EP value (unit)	RES in the EP calc.	Metric	Energy uses included	Building type	
Zone 1,2	Cyprus	100 kWh/m ² /yr	NO	Primary energy	heating, cooling, DHW, lighting	Residential	25%
		210 kWh/m ² /yr	NO	Primary energy		Non-residential	25%
Zone 3	Slovakia	33 kWh/m ² /yr	N.D.	Primary energy	heating, DHW	Apartment buildings	50%
		54 kWh/m ² /yr	N.D.	Primary energy		Family houses	50%
		60 kWh/m ² /yr	N.D.	Primary energy	heating, cooling, ventilation, DHW, lighting	Office	50%
		34 kWh/m ² /yr	N.D.	Primary energy		Schools	50%
Zone 4	Belgium (BR)	45 kWh/m ² /yr	YES	Primary energy	heating, DHW, appliances	Individual dwellings	-
		95 - 2.5*(V/S) kWh/m ² /yr	YES	Primary energy	heating, cooling, DHW, lighting, appliances	Office buildings	-
		95 - 2.5*(V/S) kWh/m ² /yr	YES	Primary energy	heating, cooling, DHW, appliances	Schools	-
Zone 4	Belgium (NL)	60 kWh/m ² /yr	N.D.	Primary energy	heating, DHW, appliances	Residential buildings, schools, office and service buildings	50%
		30 kWh/m ² /yr	YES	Primary energy	heating, cooling, ventilation, DHW, auxiliary systems	Residential	>10 kWh/m ² /yr
	Belgium (FR)	40 kWh/m ² /yr	YES	Primary energy		Office buildings, Non-residential	>10 kWh/m ² /yr
		50 kWh/m ² /yr	NO	Primary energy		Residential	-
	France	70 kWh/m ² /yr	NO	Primary energy	heating, cooling, ventilation, DHW, lighting, auxiliary systems	Office buildings, non-air-cond.	-
		110 kWh/m ² /yr	NO	Primary energy		Office buildings, air-cond.	-
Ireland	45 kWh/m ² /yr	N.D.	Energy load	heating, ventilation, DHW, lighting	Residential	-	
Netherlands	0-1-1	YES	Energy performance coefficient (EPC)	heating, cooling, ventilation, DHW, lighting	Residential/ Non-residential	not quantified, but necessary	
	20 kWh/m ² /yr	YES	Primary energy	heating, cooling, ventilation, DHW	Residential	51%- 50%	
Zone 5	Denmark	25 kWh/m ² /yr	YES	Primary energy	heating, cooling, ventilation, DHW, lighting	Non-residential	51%- 50%
		50 kWh/m ² /yr	YES	Primary energy		Detached houses	-
		100 kWh/m ² /yr	YES	Primary energy		Apartment buildings	-
		100 kWh/m ² /yr	YES	Primary energy		Office buildings	-
		130 kWh/m ² /yr	YES	Primary energy		Hotels and restaurants	-
		120 kWh/m ² /yr	YES	Primary energy	heating, cooling, ventilation, DHW	Public buildings	-
		130 kWh/m ² /yr	YES	Primary energy	lighting, HVAC, auxiliary, appliances	Shopping malls	-
		90 kWh/m ² /yr	YES	Primary energy		Schools	-
		100 kWh/m ² /yr	YES	Primary energy		Day care centres	-
		210 kWh/m ² /yr	YES	Primary energy		Hospitals	-
Lithuania	95 kWh/m ² /yr	N.D.	Primary energy	heating, cooling, ventilation, DHW, lighting	Residential/ Non-residential	-	
Lithuania	<0.25-1-1	N.D.	Energy performance indicator C	heating	Residential/ Non-residential	50%	



Net Zero: California unveils goal to achieve 'carbon neutrality' by 2045





Manchester City, UK

Vision 2050

*Manchester is playing its full part in limiting the impacts of climate change, locally and globally. It is a thriving, **zero carbon, zero waste, climate resilient city** where all our residents, public, private and third sector organisations are actively contributing to and benefiting from the city's success.*

Green Summit March 2018

- Mayor sets target of NZ city by 2040
- Requires citizens and companies to pledge support
- Manchester Tyndall Centre leads Climate change research



Manchester

Climate Change Strategy 2017-50


Manchester

Climate Change Strategy 2017-50

Implementation Plan 2017-22

Zero Energy as a Target—UK Schools

- UK—All new schools zero carbon by **2016 (not happening!)**
- Engagement
- Knowledge and skills
- Feedback on performance
- Low and zero carbon energy supplies
- Investment



London Action Plan

The mayor aims for London to be a zero carbon city by 2050, with energy-efficient buildings, clean transport, and clean energy.

Make sure that new developments are zero carbon from 2019, with clean supplies of energy and high energy efficiency designed in from the start




How do we achieve Net zero carbon London






UK Construction in crisis

- Grenfell Tower disaster – Hackitt Enquiry
- UK engineers NOT registered
 - CPD not mandatory yet !
- Certification of contractors limited and ineffective
- Building services courses closing
 - BREXIT confusion



Zero carbon means total carbon

- EU Directive and UK Building Regs only cover 'environmental energy'
- Heat, Light, cooling, hot water, ventilation
- **Not plug loads**
- **Not process loads**
- **ASHRAE – and others – includes all use**
- Net Zero Energy Cost Building
- Net Zero Energy Emissions Building



Who is Already Doing Net Zero ?

- Environmental organizations
- Research centers
- Universities and schools
- Some engineered solutions which aimed to save costs and saved energy too

Getting to Zero 2012 Status Update:

nbi new buildings institute

research report

March 2012



Getting to Zero 2012 Status Update:


A First Look at the Costs and Features of Zero Energy Commercial Buildings

With support from:



- North American review of completed NZ buildings
- Location of 21 projects

Figure 2. Location of the 21 zero energy projects



Seattle—Bullitt Center

- Opened on [Earth Day](#), April 22, 2013
- Greenest commercial building in the world
- [Living building](#)
- 6-story, 52,000 ft² (4800 m²)
- [Energy and carbon neutral](#)
- \$18.5 million, or \$355 per ft² (2013 base)



<#>

Bullitt Center—Net Zero Energy

- Energy efficiency 83% better than a typical Seattle office
- Predicted EUI rating of 16 kBtu/ft²/yr
- 242 kW photovoltaic array
- Ground-source geothermal heat exchange system
- Radiant floor heating and cooling
- Retractable external blinds to block heat before it warms the building
- Reduced plug loads



<#>

La Jolla Commons II, CoStar Group

- 13-story La Jolla Commons II office University Towne Centre
- Largest net zero energy building in United States
- 415,000 ft²
- Biogas and onsite fuel cells
- Methane to electricity, tapping methane in landfills and wastewater plants.




DEWA to Build the Tallest Zero Energy Building

- Dubai Electricity and Water Authority's (DEWA) new headquarters (HQ) will be the tallest, largest, and smartest net zero energy building (ZEB) in the world once it's completed in 2019.
- Total renewable energy generated by the building will be over 5400 megawatt hours (MWh) annually.
- Al-Sheraa's design was inspired by the traditional houses in the UAE, where enclosed spaces overlook an open courtyard.



Blackpool Council's Old Disused Solarium

- Graham Nash's hometown—a northern UK seaside town




Solaris Blackpool—A Zero Carbon Building

A Small Project by Frank Mills in 2002




Renewable Energy Systems Used

Solar Panel is mounted on the South Tower, facing South at a 45 degree angle.



Solar Hot Water



- Control?
- Avoid boiling
- Avoid freezing
- *Legionella?*

Hot-Water Panel Solar Gains




Wind Turbine on Seafront



- 6 kW electrical
- Facing the sea

Net Zero

- Generates more energy than used
- Net exporter
- Uses fossil fuels when necessary




Liverpool Sailing Club

- River Mersey
- Project budget £1M
- Remote location—no energy supplies
- New electric cable over £250k
- New gas main £250k
- Alternative renewables energy supplies only £200k
- 6 kW Wind turbine, 4 kW solar PV panels, biodiesel CHP unit, battery storage
- Integrated design—
fabric/structure/services



ASHRAE LOW CARBON GUIDES

- Ongoing publications
- Retail 50% guide now out
- Others in production
- Information on HVAC and R and Electrical systems



50%

**Advanced Energy Design Guide
for Grocery Stores**

**Achieving 50% Energy Savings
Toward a Net Zero Energy Building**

Developed by:
ASHRAE
The American Institute of Architects
Illuminating Engineering Society of North America
U.S. Green Building Council
U.S. Department of Energy

follow us
#EnergyShow19

ASHRAE 50% and NZ SCHOOLS GUIDES

Posted originally, 9/28/2011



Advanced Energy Design Guide for K-12 School Buildings

Achieving 50% Energy Savings Toward a Net Zero Energy Building

Developed by:
American Society of Heating, Refrigerating and Air-Conditioning Engineers
The American Institute of Architects
Illuminating Engineering Society of North America
U.S. Green Building Council
U.S. Department of Energy



ACHIEVING ZERO ENERGY Advanced Energy Design Guide for K-12 School Buildings




Developed by:
ASHRAE
The American Institute of Architects
Illuminating Engineering Society of North America
U.S. Green Building Council
U.S. Department of Energy

follow us
#EnergyShow19

ASHRAE HOSPITAL 50% GUIDE

- Hospital guide available



50%

**Advanced Energy Design Guide
for Large Hospitals**


**Achieving 50% Energy Savings
Toward a Net Zero Energy Building**

Developed by:
ASHRAE
The American Institute of Architects
Illuminating Engineering Society of North America
U.S. Green Building Council
U.S. Department of Energy


follow us
[#EnergyShow19](#)

ASHRAE and REHVA NZ Hospitals guide

- TC 9.6 lead
- REHVA initiative
- Dutch engineers taking the lead
- Supports EU and UK aspirations – as well as ASHRAE




Design Standards ASHRAE Beq



Three Steps to Net Zero—Be Lean

Renewables are generally most expensive option; therefore, use Stages 1 and 2 to maximum




● Stage 1 Building Envelope Measures

- *Energy Efficiency Measures*
- *Renewable Energy Measures*

Energy Efficiency—Passive Thermal Storage Using PCMs

HVAC—Passive Cooling



Energy Efficiency—Passive Thermal Storage Using PCM

HVAC—Passive Cooling

Classroom

The collage illustrates the implementation of Phase Change Materials (PCM) for passive cooling in a classroom. It features a central diagram of the PCM cycle, a worker on a ladder installing panels, a view of the completed ceiling, and a view of the classroom interior.


Charging	Phase Change	Discharging

142


Advanced Natural Ventilation



DE MONTFORT UNIVERSITY



DAYLIGHTING AND SUNLIGHTING




The principles of the natural ventilation strategy. With an emphasis on daylighting and sunlighting.



An auditorium from the concourse walkway. Note the glazed blocks in the walkway to aid daylight penetration and the exposed auditoria structure.

Last Step to Net Zero—Stage 3 Renewable Energy Systems



Renewables are generally most expensive option; therefore, use Stages 1 and 2 to maximum

- *Building Envelope Measures*
- *Energy Efficiency Measures*
- **Renewable Energy Measures**

Be Lean...Be Clean...Be Green

Courtesy of Otto Steinger.

<#>

Wind turbines can be a waste of money

Have these 2 vertical axial turbines ever worked ?




Installed to meet Planning

- We need to engineer zero carbon solutions
- ‘Bolt on’ renewables to comply with Planning Waste of money – around £50k



Renewable Energy



<#>

Toronto – zero carbon cooling



DEEP LAKE WATER COOLING SYSTEM

Acknowledge the major Net Zero cooling system in Toronto

The City of Toronto and Enwave Energy Corp.

ACCIONA

General Contractor, responsible for procurement; construction of intake pipelines, heat exchange plant, heat exchangers and valve chambers, equipment installation, testing and commissioning of the project

Infrastructure

Enwave's Deep Lake Water Cooling system

Completion date
2004


Bridlington and Hull Geothermal Study

- 1) **Data
Collection**
- 2) **Geology**
- 3) **Temperatures**
- 4) **Yield**
- 5) **Chemistry**



Geology

Geological cross section from Cleethorpes 1 (south) to Hunmanby 1 (north), see the map.
Lithology in wells through the Sherwood sandstone.
 The depth values on the proposed well in Bridlington indicates upper and the lower depth of the Sherwood sandstone, assuming a uniform dip between Rudston 2 and Barmston 1 and the depth values on the proposed well in Paull indicates upper and the lower depth of the Sherwood sandstone, assuming uniform dip between Risby 1 and Winestead 1. The temperature values are calculated using a 30 °C geothermal gradient.



Water-Source Heat Pumps

- Liverpool Docks
- Stanley tobacco warehouse and other regeneration projects could use dock water for heating and cooling



Renewable Energy from Water Sources



- Canals across the UK are being looked at as possible heat sources using heat pumps

Abandoned collieries could heat UK homes – 9th April 2018




Flooded coal mines in UK

1. UK coal industry closed down
2. All mines are disused and flooded.
3. vast reservoir of warm water fills a labyrinth of disused mines and porous rock layers underneath Glasgow
4. this subterranean store of naturally heated water could be used to warm homes in the city.
5. If successful, such water could then be exploited in other cities and towns across Britain's coal communities

Zero Energy Cities

- District energy systems
- Use surplus ambient energy from one building to feed another
- Thermal storage needed to avoid waste
- Decarbonised grid
- Infrastructure investment
- Link new building to regeneration of existing to achieve overall zero energy use
- Energy profiles essential, good data required
- Mixed use presents variable loads, which optimizes energy plant use

Zero Energy Cities





Conclusion

- Define the “zero” (site, source, carbon, or cost)
- Understand the microclimate of the site
- Design the siting, form, thermal mass of the building to maximize the use of natural energy flows and reduce external loads
- Minimize lighting energy use through effective daylighting
- Reduce plug loads as much as possible. Recover waste heat.
- Efficient HVAC systems - including natural ventilation and mixed mode
- Modelling of annual building energy consumption
- Provide renewable energy systems to offset resulting energy use
- Commission your systems and ensure proper handover to O&M staff
- Keep it working !

Panel Discussion



The Sustainable Energy Authority of Ireland is partly financed by Ireland's EU Structural Funds Programme co-funded by the Irish Government and the European Union.